

**CITY OF WALESKA**  
**PUBLIC WATER SYSTEM ID, GA0570024**  
**ANNUAL WATER QUALITY REPORT**  
**2025**

The City of Waleska met all water quality standards for 2025. The City of Waleska owns and operates its own potable water distribution system, but purchases all of its water from the City of Canton and Cherokee County Water & Sewerage Authority. In an effort to keep our citizens up to date on the condition of our drinking water, we have compiled this report as a snapshot of last year's water quality. Included are the details about where your water comes from, what it contains and how it compares to EPA and state standards. We are committed to providing you with information because informed customers are our best allies.

**Sources of drinking water** (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and in some cases, radioactive material and can pick up substances resulting from the presence of animals or from human activity.

**Your water is taken directly from the Etowah River** and is treated and filtered to remove contaminants, plus the water is chlorinated to disinfect against viruses and pathogens (harmful bacteria). Fluoride is added to enhance dental protection. The levels of these two additives are monitored daily by the City of Canton and the Cherokee County Water & Sewerage Authority to ensure proper dosages are being added. The City of Waleska acquires water from the Cherokee County Water & Sewer Authority and the City of Canton which amounts to 100% of total water sold. The Authority's and Canton's source for water is the Etowah River. A Source Water Assessment can be obtained from Cherokee County Water and Sewerage Authority via their website at <http://ccwsa.com/water/source-water-assessment/> or you can request information by mail from Cherokee County Water & Sewerage Authority:

Cherokee County Water & Sewerage Authority  
Attn: Lori Forrester, Public Information Specialist  
P.O. Box 5000  
Canton, GA 30114

**Drinking water, including bottled water** may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's **Safe Drinking Water Hotline (800-426-4791)**.

**Contaminants that may be present** in source water before it is treated include:

- *Microbial contaminants*, such as viruses and pathogens (harmful bacteria), which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- *Inorganic contaminants*, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining and farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agricultural and residential uses.
- *Radioactive contaminants*, which are naturally occurring.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production and can also come from gas stations, urban storm water runoff and septic systems.

**Some people may be more vulnerable** to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly people and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care provider. United States Environmental Protection Agency / Center for Disease Control guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbes are available from the **Safe Drinking Water Hotline (800-426-4791)**.

**In order to ensure that tap water is safe to drink**, EPA (Environmental Protection Agency) prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. We treat our water according to EPA regulations. FDA (Food and Drug Administration) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

The table below lists drinking water contaminants detected during the 2025 calendar year. Presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing performed January 1 – December 31, 2025.

Substance Detected	Maximum Containment Level	MCLG	Level Detected	Range	Violations	Likely Source(s)
Turbidity (NTU) *Results as reported by Source Water Supplier	< .5 in 95% samples	0.5	0.06	0.03 - 0.15	None	Soil Runoff
Copper (ppb) *Reported "Level Detected" is the average for all samples collected in 2025	AL=1300	<1300	81.8	7.7–170.0	None	Household Plumbing
Coliform (% Positive)	0%	0%	0%	N/A	None	Naturally Present In The Environment
Fluoride (ppm) *Results as reported by Source Water Supplier	4	4.00	0.73	.61 – 1.19	None	Water Additive for Health
Lead (ppb) *Reported "Level Detected" is the average for all samples collected in 2025	AL=15	<15	0	0	None	Household Plumbing
Nitrate (ppm) *Results as reported by Source Water Supplier	10	10.00	0.23	N/A	None	Fertilizer/ Soil Runoff
Haloacetic Acids (ppb) *Reported "Level Detected" & "Range" is derived from sample location running annual average (LRAA) data.	60	N/A	34.1	15.5 – 44.5	None	Disinfection By-Product
Trihalomethanes (ppb) *Reported "Level Detected" & "Range" is derived from sample location running annual average (LRAA) data.	80	N/A	45.1	16.6 – 73	None	Disinfection By-Product

**Compliance with Drinking Water Regulations**

All tests for contaminants, as listed above, were below the Maximum Contaminant Level as prescribed by drinking water regulations at the state and federal level.

Turbidity is a measure of the cloudiness of water and is a good indicator of water quality.

NTU is the Nephelometric Turbidity Unit.

Action Level (AL): The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements that a water system must follow.

**MCL (Maximum Contaminant Level):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**MCLG (Maximum Contaminant Level Goal):** The level of a contaminant in drinking water below which is no known or expected risk to health. MCLGs allow for a margin of safety.

**PPM:** Parts per Million (or milligrams per liter which corresponds to one gallon in 1,000,000 gallons)

**PPB:** Parts per Billion (or micrograms per liter which corresponds to one gallon in 1,000,000,000 gallons)

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Waleska is responsible for providing high quality drinking water, but cannot control the variety of materials used in private plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the **Safe Drinking Water Hotline (800-426-4791)** or at <http://www.epa.gov/safewater/lead>.

**The City of Waleska Council** meets on the 1<sup>st</sup> and 3<sup>rd</sup> Monday of each month at Waleska City Hall, with the meeting beginning at 6:30pm. These meetings are open to the public. Please contact the City Manager, at (770) 479-2912 for more information.

**2025 CCR Supplemental Lead and Copper CCR Information For (GA0570024) Water System**

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. City of Waleska is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact Lauren Garrett 770-479-2912. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

**Lead and Copper Range Data.**

Analyte	Date Sampled	MCLG	Action Level (AL)	Range		Units	Violation
				Low	High		
Lead	8-26-25	0	15	0	0	ppb	
Copper	8-26-25	1.3	1300	7.7	170	ppm	

To access all individual Lead Tap Sample results for the City of Waleska, please visit <https://cityofwaleska.com/> or contact City Hall at (770) 479-2912.